



September 11, 1998

Allen Foltman  
Big Al's Limited  
PO Box 273  
Williams Bay, WI 53191

Dear Mr. Foltman:

Wisconsin Uniform Plumbing Code (s. 82.34 (5), Wis. Adm. Code) requires that "All plumbing installations for occupancies, other than dwelling units, where grease, fats, oils or similar waste products of cooking or food are introduced into the drain system shall be provided with interceptors in accordance with this subsection."

After review of your menu and processes, our office has determined that grease interceptor will not be required. If the facility's wastewater characteristics change this department shall be notified in order to make future determinations in regards to the requirement of an interceptor.

If the processes or menu changes, or stoppages occur in the drain piping, the department may require the installation of an interior or exterior grease interceptor as per s. 82.34 (5) (a) 3, Wis. Adm. Code.

If you have further questions feel free to contact me.

Sincerely,

Lynita M. Docken  
Plumbing Program Manager  
608-785-9349 email: ldocken@Commerce.state.wi.us

Cc: Waukesha Health Department